



Report of Analysis

Mail to: Conrad Weiser Community Pool
161 S Freeman St
PO Box 95
Robesonia PA 19551

Lab Number: **337404**
Date Reported: 06/04/2021

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis					
				Date	Time	Analyst	Method	Reporting Limit	
337404-01 Sampled: 06/02/2021 16:00 Sampler: Butch Tonkin Source: PO1 Lap Pool Conrad Weiser Community Pool									
Bacteria, Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	06/02/2021	17:10	ajy	SM 9223 Colilert	0	

This sample was collected by a lab-authorized sampler.

337404-02 Sampled: 06/02/2021 16:00 Sampler: Butch Tonkin Source: PO2 Baby Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	06/02/2021	17:10	ajy	SM 9223 Colilert	0

This sample was collected by a lab-authorized sampler.



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician