



## Report of Analysis

Mail to: Conrad Weiser Community Pool  
 161 South Freeman Street  
 PO Box 95  
 Robesonia PA 19551


Lab Number: **316170**  
 Date Reported: 07/10/2020

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
316170-01 Sampled: 07/08/2020 11:55 Sampler: Derek High Source: PO1 Lap Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	0 MPN/100mL	Pass	2 MPN/100mL	07/08/2020	16:31	ajy	SM9223	0
This sample was collected by a lab-authorized sampler.								
316170-02 Sampled: 07/08/2020 11:55 Sampler: Derek High Source: PO2 Baby Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	1.0 MPN/100mL	Pass	2 MPN/100mL	07/08/2020	16:31	ajy	SM9223	0
This sample was collected by a lab-authorized sampler.								



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



**Report Approved By:**  
  
 Andrew T Heist, Lab Technician