



Report of Analysis

Mail to: Conrad Weiser Community Pool
161 S Freeman St
PO Box 95
Robesonia PA 19551

Lab Number: **341717**
Date Reported: 07/28/2021

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis					
				Date	Time	Analyst	Method	Reporting Limit	
341717-01 Sampled: 07/26/2021 12:48 Sampler: Amos Fisher Source: PO1 Lap Pool Conrad Weiser Community Pool									
Bacteria,Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	07/26/2021	14:50	ewm	SM 9223 Colilert	0	

This sample was collected by a lab-authorized sampler.

341717-02 Sampled: 07/26/2021 12:48 Sampler: Amos Fisher Source: PO2 Baby Pool Conrad Weiser Community Pool									
Bacteria,Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	07/26/2021	14:50	ewm	SM 9223 Colilert	0	

This sample was collected by a lab-authorized sampler.



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician