



## Report of Analysis

Mail to: Conrad Weiser Community Pool  
 161 S Freeman St  
 PO Box 95  
 Robesonia PA 19551

Lab Number: **342895**  
 Date Reported: 08/11/2021

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
342895-01 Sampled: 08/09/2021 12:44 Sampler: Amos Fisher Source: PO1 Lap Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	08/09/2021	14:43	rwl	SM 9223 Colilert	0

**This sample was collected by a lab-authorized sampler.**

342895-02 Sampled: 08/09/2021 12:44 Sampler: Amos Fisher Source: PO2 Baby Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	08/09/2021	14:43	rwl	SM 9223 Colilert	0

**This sample was collected by a lab-authorized sampler.**



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician