



## Report of Analysis

Mail to: Conrad Weiser Community Pool  
 161 South Freeman Street  
 PO Box 95  
 Robesonia PA 19551

Lab Number: **298504**  
 Date Reported: 08/22/2019

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
298504-01 Sampled: 08/20/2019 11:33 Sampler: Dale Fry Source: PO1 Lap Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	0 MPN/100mL	Pass	2 MPN/100mL	08/20/2019	16:30	ajy	SM9223	0
This sample was collected by a lab-authorized sampler.								
298504-02 Sampled: 08/20/2019 11:33 Sampler: Dale Fry Source: PO2 Baby Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	0 MPN/100mL	Pass	2 MPN/100mL	08/20/2019	16:30	ajy	SM9223	0
This sample was collected by a lab-authorized sampler.								



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



**Report Approved By:**

Andrew T Heist, Lab Technician