



# Report of Analysis

Mail to: Conrad Weiser Community Pool  
161 S Freeman St  
PO Box 95  
Robesonia PA 19551

Lab Number: **344113**  
Date Reported: 08/25/2021

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
344113-01 Sampled: 08/23/2021 12:52 Sampler: Amos Fisher Source: PO1 Lap Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	08/23/2021	13:57	ajy	SM 9223 Colilert	0

**This sample was collected by a lab-authorized sampler.**

344113-02 Sampled: 08/23/2021 12:52 Sampler: Amos Fisher Source: PO2 Baby Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	<1 MPN/100mL	Pass	2 MPN/100mL	08/23/2021	13:57	ajy	SM 9223 Colilert	0

**This sample was collected by a lab-authorized sampler.**



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician